

पत्रांक:-सीएफओ/अ0सु0-1/2022

दिनांक-फरवरी 15, 2022

सेवा में,

OWNER/MANAGER,
ATAL UTKRISHT GOVERNMENT INTER COLLEGE,
VILL & POST-MASI,
DISTT-ALMORA, UTTARAKHAND,

विषय:- अग्निसुरक्षा सम्बन्धी अनापत्ति प्रमाण-पत्र के नवीनीकरण के सम्बन्ध में।

कृपया उपरोक्त विषयक एवं आवेदक द्वारा किए गये आवेदन पत्र सं0-38067075 दिनांक 13/03/2022 के परिपेक्ष्य में इस कार्यालय के निर्गत आदेश दिनांक:04.03.2022 के अनुपालन में अग्निशमन अधिकारी नैनीताल द्वारा ATAL UTKRISHT GOVERNMENT INTER COLLEGE, VILL & POST-MASI, का प्राथमिक अग्निसुरक्षा दृष्टिकोण से निरीक्षण किया गया उक्त के अनुसार वर्तमान में निम्नांकित अग्निसुरक्षा व्यवस्था पाई गई।

1. परिसर में अण्डर ग्राउण्ड रिजर्व वाटर टैंक 20 हजार ली0 क्षमता एवं ओवर हैड रिजर्व वाटर टैंक 12 हजार ली0 क्षमता का प्राविधान है।

2. परिसर में 04 अदद एबीसी टाईप फायर एक्सटिंग्यूशर 04 किग्रा0 क्षमता, 01 अदद सीओ2 टाईप फायर एक्सटिंग्यूशर 4.5 किग्रा क्षमता एवं 01 अदद एएफएफएफ टाईप फायर एक्सटिंग्यूशर 09 ली0 क्षमता का प्राविधान किया गया है।

उपरोक्त के अतिरिक्त संस्थान का किसी भी कार्य दिवस में मुझ अधोहस्ताक्षरी द्वारा अग्निसुरक्षा दृष्टिकोण से निरीक्षण किया जा सकता है साथ ही निर्देशित किया जाता है कि-

1. संस्थान के विस्तार/अतिरिक्त निर्माण किये जाने की दशा में तदनुसार NBC-2016 के Part-04 में निर्दिष्ट मानकों के अनुसार अतिरिक्त अग्निसुरक्षा व्यवस्था किया जाना अनिवार्य होगा।

2. संस्थान/परिसर में प्रत्येक समय पानी रिजर्व रखा जाना अनिवार्य होगा तथा स्थापित अग्निसुरक्षा व्यवस्था की कार्यक्षमता ब रख-रखाव को प्रत्येक समय उच्च स्तर पर बनाय रखेगे।

3. सभी बाहर निकलने या बचाव के रास्ते, सैटबैक प्रत्येक दशा में अवरोध मुक्त रखी जायें।

4. आपके संस्थान में कार्यरत कर्मचारियों को उपलब्ध अग्निशमन यन्त्रों का सुरक्षित निष्करण प्रक्रिया (Evacuation) का ज्ञान होना आवश्यक है।

5. विद्युत स्विच बोर्ड/विद्युत पैनल के आस-पास तथा निकास मार्ग, भवन सैट बैक क्षेत्र में किसी संयंत्र का भण्डारण नहीं किया जायेगा, भण्डारण किये जाने पर यह प्रबन्धन की लापरवाही मानी जायेगी तथा भविष्य में अग्निसुरक्षा घटित होने पर बीमा दावे हेतु संस्तुति नहीं की जायेगी।

6. प्रत्येक 03 वर्ष से पूर्व इस कार्यालय से अग्निशमन यन्त्रों का परीक्षण कराकर (नियमानुसार 10 ली0 प्रति फायर एक्सटिंग्यूशर टैस्टिंग शुल्क) निर्धारित शुल्क-(फायर सर्विस हैड 0070 अन्य प्रशासनिक सेवाएं 80 अन्य नियम 100 अग्नि से संरक्षण एवं नियन्त्रण कराया जायेगा) अग्निशमन अनापत्ति प्रमाण-पत्र का नवीनीकरण कराया जाना अनिवार्य होगा। प्रमाण-पत्र नवीनीकृत नहीं कराये जाने की दशा में यह अनापत्ति प्रमाण-पत्र स्वतः ही निरस्त समझा जायेगा। साथ ही प्रत्येक छः माह में भवन अथवा परिसर में अग्निसुरक्षा व्यवस्था एवं उपकरणों की स्थिति सत्यापनक एवं कार्यशील होने का स्व-घोषणा प्रमाण-पत्र/Self Audit Report प्रस्तुत/अपलोड करना होगा।

7. निर्गत अग्निसुरक्षा प्रमाण-पत्र का उपयोग किसी अवैध निर्माण/कच्चे को नियमित करने के लिए मास्य नहीं होगा।

अतः इस कार्यालय से दिये गये निर्देश/सुझाव तथा शर्तों का पालन किए जाने एवं अग्निशमन अधिकारी नैनीताल द्वारा मुझ अधोहस्ताक्षरी कार्यालय को प्रेषित संस्तुति आख्या पत्रांक-अ0सु0व्यय0/RS RKT/2022 के आधार पर ATAL UTKRISHT GOVERNMENT INTER COLLEGE, VILL & POST-MASI, को दिनांक-16 मार्च 2022 से 14 मार्च 2025 तक अधिभोग (Occupancy)/अध्यासन किए जाने हेतु अग्निसुरक्षा दृष्टिकोण से इस कार्यालय को कोई आपत्ति नहीं है।

अनापत्ति-प्रमाण-पत्र निर्गत किया जाता है।

मुख्य अग्निशमन अधिकारी
मुख्य अग्निशमन अधिकारी
नैनीताल हल्द्वानी

प्रधानाचार्य
अ.प्र. रा.ह.का.
नैनीताल

Treasury Form-209(1)
Financial Handbook Vol. V, Part- II
Form No. 43A(1)
(See Paragraph 417 and 478)
Challan form for depositing amount



Name of the Treasury/Sub-Treasury/Bank/Bank Branch - State Bank Of India (Payment Gateway)

Status : (S) Completed successfully.

1	Name of the person (designation if necessary or Organization on whose behalf amount is being paid)	PRINCIPAL A U G I MASI ALMORA
2	Address	Post office Masi
3	Registration Number (if necessary)	
4	Full details of amount to be deposited (for which purpose and in favour of)	Renewal Of Fire Certificate
5	Gross value of Challan	50
6	Net value of Challan	50
7	Department	Director General Police
8	Related office for which challan is to be deposit	Superintendent of Police Almora
9	Full details of Head of Account	0070 - Other Administrative Services
10	13 Digit code of Head of A/c	As per details below

SL No.	Services	Detail Head	Amount
1	Fire Vsulia in relation to the services went by Brigade.	0070601090100	50
	Total Challan Amount-		50

Amount (in words) - Rs. Fifty only

Signature of departmental officer with seal

PRINCIPAL A U G I MASI ALMORA

Challan No- 00701225E0049630	Amount in Figure(Rs.) - 50
Date - 19-DEC-2025	Amount in words - Rs. Fifty only
Received Through	
Bank Ref. No. - IK0DMTBSF4	
State Bank Of India (Payment Gateway)	

R. Singh
प्रधानाचार्य
अटक उत्कृष्ट रा.इ.का.
मासी (अल्मोड़ा)
19/12/2025

KOKILA ASSOCIATE

Near Devi Mandir, Canal Bypass Road
Rautela Compound, Damuvadhunga, District:-Nainital
Kathgodam, Uttarakhand - 263126

Name : LOCHAN SINGH RAUTELA
Phone : 7895291997
Email : kokilaassociate21@yahoo.com

GSTIN : 05BOKPR7680L1Z5

Bill of Supply

ORIGINAL FOR RECIPIENT

Declaration : Composition Taxable Person Not Eligible To Collect Taxes On Supplies

Customer Detail

Name Government Inter College Maasi
Address Maasi, Chaukhutiya, district:-Almora,
Maasi, Maasi, Uttarakhand - 263658
Phone -
GSTIN -
Place of Supply Uttarakhand (05)

Invoice No.

17

Invoice Date

13-Apr-2026

Sr. No.	Name of Product / Service	HSN / SAC	Qty	Rate	Total
1	Refilling ABC Type Fire Extinguisher 04 kg	998721	4.00 NOS	1,150.00	4,600.00
2	Refilling co2 type fire Extinguisher 4.5 kg	998721	2.00 NOS	1,300.00	2,600.00
Total			6.00 NOS		7,200.00

Total in words

SEVEN THOUSAND TWO HUNDRED RUPEES ONLY

Total Amount

₹7,200.00

(E & O.E.)

Bank Details

Name state bank of India (S.B.I.)
Branch TEDHI PULIA
Acc. Name KOKILA ASSOCIATE
Acc. Number 40565983476
IFSC SBIN0015153
UPI ID lochanrautela355@oksbi



Pay using UPI

Terms and Conditions

Subject to our home Jurisdiction.
Our Responsibility Ceases as soon as goods leaves our Premises.
Goods once sold will not taken back.
Delivery Ex-Premises.

Certified that the particulars given above are true and correct.

For KOKILA ASSOCIATE

Kokila Associate
Near - Devi Mandir, Canal Road,
Rautela Compound, Kathgodam
263126, Dist - Nainital (Uttarakhand)
Mob. - 7017315930

Authorised Signatory

AWADH ENTERPRISES

OFFICE:- Devalchaour road, paslem vihar, Haldwani Distt. - Nainital
Ref No:-AW/11/24/47-41

Date:-10/0426

CERTIFICATE


This is to certify that we have carried out Hydro static pressure testing of the Following Fire Extinguisher at Government Inter College Maasi , Maasi Chaukhtiya district:-Almora

Test details are given below:-

Date of Testing	Fire Exting.No.	Type of fire Extn.	Working Pressure (Psi)	Duration of pressure Testing	Test Pressure Kg/Cm ³	Test Interval Year	Remark
10-04-2026	01 to 05	ABC 04 Kg.	195 psi	2.5 min	35	03	ok

Test Result: All the above Fire Extinguishers have passed hydro pressure testing.

For Awadh Enterprises



Proprietor

(Sign and stamp of contractor)

Date:-10/04/26

Place: Haldwani